

**ADDENDUM NO. 1**  
*CHICO AREA RECREATION & PARK DISTRICT*  
*COMMUNITY PARK TENNIS COURT RESURFACING PROJECT*

This addendum shall be attached to and become part of the Contract Documents. This addendum **shall be signed by the Bidder, dated and submitted with the Bid Proposal** for the project. This addendum covers the following items as numbered below:


1. Clarification: All existing tennis and pickleball court nets shall be removed by CARD prior to the start of construction and replaced after completion. CARD shall also remove the existing tennis net posts on court #2 and install the four set of net posts needed for the new pickleball courts that are proposed on the existing court #2.
2. Clarification: The existing 2'-10" chain link fence shall be extended to 6' tall, not 12' tall, between courts #2 and #3 as shown in Attachment D.

The 4' tall chain link dividing fencing between the pickleball courts as shown on Attachment D shall match existing dividing fencing on court #1. Materials for fencing include 2 7/8" schedule 40 terminal post, 2 3/8" schedule 40 line post, 1 5/8" structural top rail, 7 gauge tension wire, 8 gauge heavy duty green vinyl coated fabric.

3. Clarification: Existing entry gates will be adjusted to clear the new surface by CARD after completion of the resurfacing but prior to the site being open to the public.

Dated: March 2, 2018

Prepared By:



NORTHSTAR

Bidder:

\_\_\_\_\_

Name

\_\_\_\_\_

Street or P.O. Box

\_\_\_\_\_

City, State, Zip Code

\_\_\_\_\_

Signature

\_\_\_\_\_

Dated:

Sign date and return this addendum with the Bid Proposal.